



MANDELL ENVIRONMENTAL CONSULTING

409 MINNISINK ROAD ♦ SUITE 204 ♦ TOTOWA, NJ 07512 ♦ (973) 785-7574 ♦ FAX (973) 785-0561

Limited Water Sampling Report

Project Name: The Leaguers Head Start

Project Location: 182 Van Buren Street, Newark, NJ

Date of Sampling: September 25, 2025

Limited water sampling was performed by Mandell Environmental Consulting at The Leaguers Head Start, 182 Van Buren Street, Newark, NJ. Water samples were collected from the kitchen sink faucet. Samples were also collected from 50% of the other indoor water faucets utilized by the child care. The samples were collected prior to water being used in the building for a minimum of 8 hours and not longer than 48 hours. The samples were collected in 250 milliliter (ml) containers accordance with New Jersey Regulations

The samples collected were submitted for analysis to York Analytical Laboratories, 2161 Whitesville Road, Toms River NJ 08755, NJ certification # 15001. Samples were analyzed by Method SM3113B AND SM 3111B. The following table contains the results of the sampling. The maximum contaminant level (MCL) for lead in drinking water is 15 ug/L and copper 1,300 ug/L. (Laboratory Results and sampling forms Attached).

Sample Date 09/25/2025

Sample Number	Source	Results Lead	Results Copper	Units	Pos/Neg
182-1	Outlet 2	ND	152	ug/L	Neg.
182-2	Outlet 3	ND	58.8	ug/L	Neg.
182-3	Outlet 6/ Kitchen	ND	121	ug/L	Neg.
182-4	Outlet 4	ND	121	ug/L	Neg.

ND- Non Detected

The laboratory results show that none of the samples were found to exceed the lead in drinking water action level of 15 ug/L and copper 1,300 ug/L. Sampling forms and diagram are attached.

Sampling Performed by: Cheo Green
NJ Lead Inspector/Risk Assessor
Mandell Environmental Consulting
409 Minnisink Road, Suite 204
Totowa, NJ 07512

Signed: Cheo Green Date: 10-17-2025



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Mandell Lead Inspectors
409 Minnisink Road, Suite 204
Totowa, NJ 07512

Project ID : The Leaguers Head Start 182 Van Buren Street Newark, NJ
PAS Project ID : P25-10606

Matrix : Drinking Water
Report Date : 10/9/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-10606-01	182-1 Outlet 2	Copper	152	ug/L	1	50.0	22.6	1300 *	SM 3111 B	9/25/25 07:30	10/3/25 12:02
P25-10606-01	182-1 Outlet 2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/25/25 07:30	10/1/25 14:54
P25-10606-02	182-2 Outlet 3	Copper	58.8	ug/L	1	50.0	22.6	1300 *	SM 3111 B	9/25/25 07:32	10/3/25 12:03
P25-10606-02	182-2 Outlet 3	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/25/25 07:32	10/1/25 14:58
P25-10606-03	182-3 Outlet 6	Copper	121	ug/L	1	50.0	22.6	1300 *	SM 3111 B	9/25/25 07:34	10/3/25 12:04
P25-10606-03	182-3 Outlet 6	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/25/25 07:34	10/1/25 15:03
P25-10606-04	182-4 Outlet 4	Copper	121	ug/L	1	50.0	22.6	1300 *	SM 3111 B	9/25/25 07:35	10/3/25 12:05
P25-10606-04	182-4 Outlet 4	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	9/25/25 07:35	10/1/25 15:07

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

(Complete for each school)

Naturalist


Date Completed:

Indoor water faucet
FP = Food preparation

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.



182 VAN BUREN STREET
NEWARK NJ

Mandell Lead Inspectors, Inc

dba

**MANDELL ENVIRONMENTAL
CONSULTING**

409 Minnisink Road, Suite 102, Totowa, NJ 07512

T: 973-785-7574* F: 973-785-0561

mandelllead@verizon.net * www.mandellenvironmental.com

Attachment D - Filter Inventory (Complete for each school)

Name of School: THE LEAGUES HOOD STREET Grade Levels: _____

Address: 182 VAN BUREN STREET NEWARK NJ

Individual School Project Officer Signature: _____ Date: _____

[illegible]